

GOVERNMENT OF ANDHRA PRADESH
ROADS AND BUILDINGS DEPARTMENT

From:
N. Krishna Naik,
Executive Engineer
(R&B) Division, Vijayawada

To
The Pricipal
Ravindra Bharathi's Nextgen School,
Dr.No.13-583,585 &586
Pantakaluva Road, Tulasinagar
Vijayawada

Letter No. RB/SC/ECII/2022 Date: 20 .08.2022

Sir,

Sub:-(R&B) Division, Vijayawada – Soundness Certificate for RAVINDRA BHARATHI'S
NEXTGEN SCHOOL, Door.No, 13-583,585 & 586 Pantakaluva Road, Tulasi Nagar,
Vijayawada - renewal of sound ness certificate –Issued – Reg.

Ref:- 1.) Representation of the for the Principal, Ravindra Bharathi's Nextgen School,
Tulasi Nagar, Vijayawada.

##


I have to inform that the Deputy Executive Engineer (R&B) Buildings Sub-Division,
Vijayawada has inspected for RAVINDRA BHARATHI'S NEXTGEN SCHOOL, Door.No.13-583, 585
& 586, Pantakaluva Road, Tulasi Nagar, Vijayawada, N.T.R District on 06-08-2022 and
submitted the Soundness Certificate of the School building for the period from 16-08-2022 to
15-08-2023 (One year) and same is here with enclosed.

Encl: Soundness Certificates.

Yours faithfully



Executive Engineer
(R&B) Division, Vijayawada


20/8/2022

SOUNDNESS CERTIFICATE

1	Address of the School/ College	:	RAVINDRA BHARATHI'S NEXTGEN SCHOOL, Dr no 13-583,585 & 586 Pantakaluva Road, Tulasinagar, Vijayawada.
2	College/ School Running in	:	RCC Building
3	No of floors	:	G+2
4	Silt Floor/ground floor used as	:	Class Rooms
5	constructed in the year	:	2010
6	constructed As per approved plan	:	yes
7	present period up to which certificate is in force	:	25/02/2022
8	Any crakes developed in the walls in	:	No
9	Condition of lintels and walls above the	:	Satisfactory
10	Condition of beams and the Trusses	:	Satisfactory
11	Development of Cracks	:	Nil
12	Exposed reinforcement if any	:	Nil
13	Condition of Doors and Windows	:	Satisfactory
14	The width of the staircase flight is	:	1.20m against required minimum of 1.50m
15	Tread width is	:	0.30m against required minimum of 0.30m
16	The height of rise	:	0.12 m against maximum of 0.15m
17	The height of railing	:	1.00m against required minimum of 1.20m
18	The height of Corridor parapet wall	:	0.82m
19	Doorway dimensions	:	Width is 0.85m against required minimum of 1.00m & 2.02m height against 2.00m
20	Height of Parapet wall	:	0.95m
21	Internal corridor width	:	1.36m
22	Any Cantilever corridors	:	NA
23	Number of exits	:	1 No
24	There is high tension electricity lines passing near to the building	:	No
25	There is Petrol/Gas stations near to the	:	No
26	Grills are provide for all sides of balconies as children safety point of view	:	Yes

N/Sw 20/8/22
EXECUTIVE ENGINEER
Roads & Buildings Vijayawada

20/8/22

27	Building plan submitted	:	Yes
28	Building Foundation and Structural design submitted	:	No
29	Building was last painted in the year	:	2020
<p>The management is advised to attend the short falls identified in the above items and submit the details in this office, Otherwise soundness Certificate will not be renewed by the department.</p> <p>How ever for the building is safe for a period of One Year i.e., from 16.08.2022 to 15.08.2023</p>			

DMS Praveen Kumar
Assistant Executive Engineer, (R&B)
Buildings, Section-V, Vijayawada.

[Signature]
Deputy Executive Engineer, (R&B)
Buildings Sub Division, Vijayawada.

Counter signed

[Signature]
EXECUTIVE ENGINEER
Roads & Buildings Vijayawada

20/8/22

EXECUTIVE ENGINEER
Roads & Buildings Vijayawada