Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated: 28/3/2026

It is certified that an inspection team headed by Sri. V. Raja Rao. Senior Water Analyst.
(Name of Officers with designation) from Regional Public Health Laboratory. Guntur, PHED
inspected the Ravindra Bharathi's Nextgen School. D.No 22-82. Gollapudi (V) Vijayawada Rural. NTR. Dt.
(Name & Address of the school) on 26-3-2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 2164, 2165 dated 26-3-2026,
of Regional Public Health Laboratory. (PHED Lab) certified that
the RAVINDRA BHARATHI'S NEXTGEN SCHOOL. (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...One year.

28/3

Signature with Seal: .....
Name : V. RAJA RAO.
Designation : Senior Water Analyst.
Name & Address of the Office / Department : Regional Public Health Laboratory.

To Ravindra Bharathi's Nextgen School.
D.No 22/82. opp. Vadlamudi Plaza,
(Name & Address of the Institution)
Gollapudi (V).
Vijaya Wada Rural, NTR. Dt.

Senior Analyst (Regional)
Regional Laboratory
Medical College Campus
Guntur-4.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

O/o Civil Surgeon Bacteriologist Regional Laboratory GUNTUR

V. Sarathi
Secretary and Correspondent
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225

K. Sowjitha
Principal
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225

CamScanner

GOVERNMENT OF ANDHRAPRADESH
DIRECTORATE OF I.P.M.PH.LABS, FOOD (H) ADMN, Mangalagiri,Guntur.
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALSYSIS OF WATER

Sample from	RAVINDRA BHARATHI'S NEXTGEN SCHOOL, D.No: 22-82,opp Vadlamudi Plaza, Gollapudi(V), Vijayawada Rural,NTR Dt.	Lab. Ref. No:	2164
		Collected on	26.03.2026
		Received on	26.03.2026
Collected by	Staff.	Source Profile	Ro Water

S. No	Parameter	Source / Sample: Drinking water tap (Ro) at above adderess.	Limits as per IS 10500:2012: Desirable (Acceptable limit)	Limits as per IS 10500:2012: Permissible limit in the absence of alternative source
	Physical Parameters			
1	Colour (Hazen units)	<5.0	5	15
2	Turbidity in NTUS``	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeable
4	pH	6.9	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	210	...	
6	TDS (mg/L)	138	500	2,000
	Chemical parameters (mg/L)			
1	Alkalinity (as $CaCO_3$)	Nil	...	
2	Total Alkalinity. Max	32	200	600
3	Total hardness max	40	300	600
4	Calcium hardness (as $CaCO_3$)	20	..	
5	Magnesium hardness (as $CaCO_3$)	20	..	
6	Calcium (as Ca)	8.0	75	200
7	Magnesium (as Mg)	5.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	36	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample physico chemically all the analysed parameters are within the desirable limits and Satisfactory for drinking purpose.

Office of the Civil Surgeon Bacteriologist Regional Laboratory GUNTUR

28/3

Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4

V. Savithri
Secretary and Correspondent
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225

K. Savitha
Principal
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Mangalagiri,Guntur
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from:.RAVINDRA BHARATHI'S NEXTGEN SCHOOL,D.No: 22-82,opp Vadlamudi Plaza, Gollapudi(V),Vijayawada Rural,NTR Dt.

llected on: 26.03.2026 **Received on :** 26.03.2026 **Paid / Free :** paid

Collected by : Staff.

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MPN of Esch. coli.
1	2165	Drinking water tap(Ro) at above adderess.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically Satisfactory for drinking purpose as evidenced by the Nil MPN count of coliform bacteria.

Civil Surgeon Bacteriologist Regional Laboratory GUNTUR

28/3
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur-4.

V. Sarathi
Secretary and Correspondent
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225

K. Saritha
Principal
Ravindra Bharathi's Nextgen school
Opposite Vadlamudi Plaza, Gollapudi (V),
Vijayawada Rural, NTR District -521225